



THE ASSAM GAZETTE

অসাধাৰণ

EXTRAORDINARY

প্ৰাপ্ত কৰ্তৃত্বৰ দ্বাৰা প্ৰকাশিত

PUBLISHED BY THE AUTHORITY

নং 18 দিশপুৰ, বুধবাৰ, 18 জানুৱাৰী, 2017, 28 পূহ, 1938 (শক)

No. 18 Dispur, Wednesday, 18th January, 2017, 28th Pausa, 1938 (S.E.)

GOVERNMENT OF ASSAM

ORDERS BY THE GOVERNOR

INSPECTORATE OF ELECTRICITY

OFFICE OF THE CHIEF ELECTRICAL INSPECTOR CUM-ADVISER, ASSAM

NOTICE

The 5th November, 2016

No. CEIA/Misc-397/155.- In the interest of Safety in general and Public Safety in particular, in exercise of the powers vested upon me under the Electricity Act, 2003 (hereinafter referred to as the "Act") and the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010 (hereinafter referred to as the "CEA Regulations") made thereunder in force from time to time and as amended up to date; these are to implore and require every owner of every electrical installation having more than 250 KW of electrical load and situated within the State of Assam and coming under purview of regulation 3 & 5(4) of the CEA Regulations read with Section 54 of the Act and regulation 12 of the Regulations; to make the following arrangements in their electrical installation directly or through appropriate agent of the owner or an appropriate contractor who entered into contract with the owner to carry out duties incidental to generation, transformation, transmission, conversion, distribution or use of electricity in the electrical installation of the owner:

(1) Designate appropriately qualified "Electrical Safety Officer" for ensuring the observance of the safety provisions laid under the Act and the CEA Regulations made thereunder, who shall carryout recommended periodic tests as per the relevant standards,

and inspect such installation at intervals not exceeding one year, and keep a record thereof in Form I or Form II or Form III, as the case may be, of Schedule IV to the CEA Regulations; test report and a register of recommendations 10 regard with safety duly acknowledged by owner; compliances made thereafter; and such records shall be made available to the Chief Electrical Inspector and/or Electrical Inspector having jurisdiction, as and when required;

(2) Designate adequate number of persons possessing valid electrical Supervisor's Certificate of Competency or electrical Workmen Permit issued by the Assam Electrical Licensing Board, for the purpose to operate and carryout the work on electrical lines and apparatus covering the daily power duty cycle of the electrical installation without leaving that unattended and without prejudice to the provisions of regulation 29 of the CEA Regulations and applicable Labour Laws.

These may be treated as orders within meaning of Section 162 of the Act and hereby made bonafide to the causes stated above, However, an appeal may be filed against these orders under the same Section of the same Act, within 3 (three) calendar months from this 05th day of the month of November of the year 2016 of Gregorian calendar, if deemed be needed so, but these orders shall be complied with; notwithstanding such appeal, unless the appellate authority on or before the specified period of 3 (three) calendar months, suspends its operation.

NURUL HUDA,

Chief Electrical Inspector to the Government of Assam,
An Officer authorized U/S. 162 of the Electricity Act, 2003.